



ICONS and Innovators Webinar Series
CEU Verification Form & Quiz

To earn AIA Continuing Education Units, purchase a CEU Management fee, complete the verification form and quiz questions and submit to Natalie Gonzalez at ngonzalez@healthdesign.org.

Participant Name: _____

AIA Member #: _____

Provider Name: **The Center for Health Design** Provider Number: **Z009**

I purchased a CEU Management fee Order # _____

Attended	AIA	Webinar Title	LU Hours	HSW
Yes <input type="checkbox"/> No <input type="checkbox"/>	WEB22C28_ON	Life Safety in Behavior Health Designs: Are There Conflicts?	1.0	Yes

1. Manual fire alarm boxes are not required at the exits if provided at the nurses control station and the following requirement is met:
 - a. Automatic smoke detection is provided in each sleeping room
 - b. The spaces served is not a patient sleeping area
 - c. Travel distance to the box does not exceed 100 ft
 - d. Travel distance to the box does not exceed 200 ft

2. Doors that swing out into the corridor may not reduce the width of the corridor by more than _____ during at any point in the door swing
 - a. ½ the required width of the corridor
 - b. 7 inches
 - c. 21 inches
 - d. 48 inches

3. Sliding doors are permitted to be used for patient sleeping rooms provided which of the following conditions is met:
 - a. There is no more than 1 patient assigned to the room
 - b. The occupant load of the room served is less than 10 people
 - c. The door is power operated
 - d. Such doors are not permitted without a break-away feature

4. Doors to patient sleeping rooms may be locked to prevent access by anyone other than the patient from the corridor side.
 - a. True
 - b. False

NOTE: To have your credit uploaded to the AIA, you must purchase a CEU Management fee from The Center for Health Design store. This \$12.00 fee covers the administrative cost of uploading CEUs to the AIA. <https://www.healthdesign.org/store/products/events-webinars>

ICONS and Innovators Webinar Series

CEU Verification Form & Quiz

5. For purposes of determining allowable locking arrangements, which of the following is NOT considered a clinical need of the patient:
 - a. Behavioral health
 - b. Dementia
 - c. Detention units
 - d. Maternity units

6. Where doors to patient sleeping rooms are to be locked due to the clinical needs of the patient, a smoke detector is required within the patient sleeping room.
 - a. True
 - b. False

7. More than one lock per door is permitted on sleeping room doors when:
 - a. It is an existing health care occupancy
 - b. The AHJ approves more than one lock per door
 - c. All of the above
 - d. More than one lock per door is not permitted.

8. If delayed egress locks are to be used, which of the following applies:
 - a. The building must be protected with an automatic sprinkler system or an automatic detection system
 - b. No more than one delayed egress lock is permitted in an egress path
 - c. Delayed egress locks are not permitted in health care occupancies
 - d. a and b

9. In a health care occupancy, access control locks must be unlocked upon actuation of the fire alarm system, other than manual fire alarm boxes
 - a. True
 - b. False

10. Spaces are permitted to be open to the corridor in a health care occupancy provided:
 - a. The space is not used for patient sleeping
 - b. The space is used as a nurses' station
 - c. The smoke compartment is protected throughout with automatic sprinkler system
 - d. a or b

NOTE: To have your credit uploaded to the AIA, you must purchase a CEU Management fee from The Center for Health Design store. This \$12.00 fee covers the administrative cost of uploading CEUs to the AIA. <https://www.healthdesign.org/store/products/events-webinars>